JRA STANDARD DRAWINGS

PROPOSED AMENDMENTS OCTOBER 2007

Delete		Add	
Drawing No	**Action**	**Drawing No**	**Action**
JRA-SD-R002	Replace.	(JRA-SD-R002)	CoJ minimum standards + combined notes.
JRA-SD-R005	Note 8 : omit Ralumac.	JRA-SD-S008	Salberg KI details.
JRA-SD-R006	Note 6 : omit Ralumac.		
JRA-SD-R007A	Identify drain type.		
JRA-SD-R012	Haunching should be continuous.		
JRA-SD-R012A	Haunching should be continuous.		
JRA-SD-R013	Haunching should be continuous.		
JRA-SD-S006A	Manhole cover detail required. Slab thickness required.		
JRA-SD-S009	Circular opening should be 600.		
JRA-SD-S019	Dimension of 2170 should be B.		
JRA-SD-S020	Cutoff wall should be 600 deep.		
JRA-SD-S025	Notes incomplete. Table should be specified.		